

**Lead and Copper Sampled in the Distribution System  
Lead and Copper Individual Sample Results**

Contaminant Name	Time Period	Tap Sample Range Low - High	90 <sup>th</sup> Percentile	Sample Size	Unit of Measure	90 <sup>th</sup> Percentile AL	Sample Sites Above AL	90 <sup>th</sup> Percentile AL Exceedance	Typical Sources
	08/15/2024								systems; Erosion of natural deposits
Lead	08/15/2024 to 08/15/2024	0 to 1.5	0.6	10	ppb	15	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

**Disinfection Byproducts Sampled in the Distribution System**

Name	Year	Average	Range Low - High	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation	Typical Sources
Total Haloacetic Acids (HAA5)	2024	1.6	1.6 to 1.6	1	ppb	60	N/A	No	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM)	2024	6.8	6.8 to 6.8	1	ppb	80	N/A	No	Byproduct of drinking water disinfection